



TEST REPORT

MODEL NAME : UPF100S36CQH

1. DESIGN VERIFY TEST
 - 1-1. INPUT FUNCTION TEST
 - 1-2. OUTPUT FUNCTION TEST
 - 1-3. PROTECTION FUNCTION TEST
2. SAFETY&EMC TEST
3. RELIABILITY TEST

1. DESIGN VERIFY TEST

1-1. INPUT FUNCTION TEST

TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT	VERDICT
VOLTAGE RANGE	90~305VAC	I/P: testing O/P:full load Ta:25 °C	test ok	P
FREQUENCY RANGE	47~63Hz no damage osc	I/P:90~305VAC O/P:full~min. load Ta:25 °C	test ok	P
POWER FACTOR	0.95 min.	I/P:115VAC I/P:230VAC O/P:full load	PF=0.997/115VAC PF=0.96/230VAC	P
EFFICIENCY	90% typ.	I/P:230VAC O/P:full load Ta:25 °C	91.1%	P
AC CURRENT	1.0A/115VAC typ. 0.6A/230VAC typ.	I/P:115VAC I/P:230VAC O/P:full load Ta:25 °C	0.94A/115VAC 0.478A/230VAC	P
INRUSH CURRENT	40A typ. cold start	I/P:230VAC O/P:full load Ta:25 °C	37A	P
LEAKAGE CURRENT	2.5mA max.	I/P:230VAC O/P:min. load Ta:25 °C	2.1mA	P

1-2. OUTPUT FUNCTION TEST

TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT	VERDICT
OPERATING VOLTAGE RANGE	O/P:22~40V/2.8A±5%	I/P:230VAC O/P:CV mode Ta:25 °C	O/P=22V:2.8A O/P=40V:2.5A	P
CURRENT ADJ. RANGE	2.8A-30%/+5%	I/P:230VAC O/P:full load Ta:25 °C	1.5~3.1A	P
RIPPLE&NOISE	150mVp-p max.	I/P:230VAC O/P:full load Ta:25 °C	120mV p.p	P

SETUP TIME	3000ms/115VAC max. 3000ms/230VAC max.	I/P:115VAC I/P:230VAC O/P:full load Ta:25 °C	740ms/115VAC 320ms/230VAC	P
RISE TIME	100ms/115VAC max. 100ms/230VAC max.	I/P:115VAC I/P:230VAC O/P:full load Ta:25	9.2ms/115VAC 8.4ms/230VAC	P
HOLD UP TIME	50ms/115VAC typ. 50ms/230VAC typ.	I/P:115VAC I/P:230VAC O/P:full load Ta:25	39ms/115VAC 38.8ms/230VAC	P

1-3. PROTECTION FUNCTION TEST

TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT	VERDICT
SHORT PROTECTION	short every output 1 hour no damage	I/P:305VAC O/P:full load Ta:25 °C	no damage, recovers automatically after fault removed	P
OVER VOLTAGE PROTECTION	115~140%	I/P:115VAC I/P:230VAC O/P:min. load Ta:25 °C	130%/115VAC 130%/230VAC recovers automatically after fault removed	P
OVER TEMP. PROTECTION	temp. sensor: 95±10 °C no damage	I/P:230VAC O/P:full load	O.T.P active, automatically after fault removed	P

2. SAFETY & EMC TEST

TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT	VERDICT
WITHSTAND VOLTAGE	I/P-O/P:3.75KVAC/1min<10mA I/P-F/G:2KVAC/1min<10mA O/P-F/G:1.5KVAC/1min<10mA	I/P-O/P:3.75KVAC/1min I/P-F/G:2KVAC/1min O/P-F/G:1.5KVAC/1min Ta:25 °C	I/P-O/P:3.7mA I/P-F/G:2.8mA O/P-F/G:2.5mA no damage	P

ISOLATION RESISTANCE	I/O-O/P:500VDC>100MΩ I/O-F/G:500VDC>100MΩ O/P-F/G:500VDC>100MΩ	I/P-O/P:500VDC I/P-F/G:500VDC O/P-F/G:500VDC Ta:25℃	I/P-O/P: ∞ I/P-F/G: ∞ O/P-F/G: ∞ no damage	P
SURGE	IEC61000-4-5 industry L-N:4KV L,N-PE:6KV	I/P:230VAC/50Hz O/P:full load Ta:25℃	criteria A	P

3. RELIABILITY TEST

TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT	VERDICT
LOW TEMP. TURN ON TEST	turn on after 2hour	I/P:230VAC O/P:full load Ta:-40℃	test ok	P
STORAGE TEMP. TEST	no damage	1.thermal shock temp.: -40~+80℃ 2.test time low & high temp.:30min/each 3.total cycle:5cycle 4.input/output condition:static	test ok	P
HIGH VOLT. HIGH TEMP. HIGH HUMI. TEST	no damage after 12hour	I/P:305VAC O/P:full load Ta:70℃ HUMI.:95%RH	test ok	P
THERMAL SHOCK TEST	no damage	1.thermal shock temp.: -40~+70℃ 2.test time low & high temp.:30min/each 3.total cycle:10cycle 4.input/output condition: 230VAC full load, AC on/off test (turn on 58sec,turn off 2sec)	test ok	P
VIBRATION TEST	no damage	1.CATON&1SET 1.wave form:sine wave 2.frequency:10~500Hz 3.sweep time:12min./sweep cycle 4.acceleration:5G 5.test time:72min. in each(X,Y,Z) 6.Ta:25℃	test ok	P